

Copper (ppm)	1.3	1.3	.300 ppb	2013	0	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
<b>Special Monitoring and Unregulated Contaminant **</b>		<b>Level Detected</b>		<b>Year Sampled</b>		<b>Comments</b>
Sodium (ppm)		27		2015		Typical source is erosion of natural deposits

<sup>\*</sup> EPA considers 50 pCi/l to be the level of concern for beta particles.

<sup>\*\*</sup> Unregulated contaminants are those for which EPA has not established drinking water standards. Monitoring helps EPA to determine where certain contaminants occur and whether it needs to regulate those contaminants.

**Information about lead:** If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Village of Eau Claire is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Microbial Contaminants	MCL	MCLG	Number Detected	Violation Yes / No	Typical Source of Contaminant
Total Coliform Bacteria	>1 positive monthly sample (>5.0% of monthly samples positive)	0	0	NO	Naturally present in the environment
Fecal Coliform and <i>E. coli</i>	Routine and repeat sample total coliform positive, and one is also fecal or <i>E. coli</i> positive	0	0	NO	Human and animal fecal waste

**Monitoring and Reporting to the DEQ Requirements:** The State and EPA require us to test our water on a regular basis to ensure its safety. We met all the monitoring and reporting requirements for 2015.

We will update this report annually and will keep you informed of any problems that may occur throughout the year, as they happen. Copies are available at The Eau Claire Village Hall. We invite public participation in decisions that affect drinking water quality. The Eau Claire Village Council meets every third Monday of each month. For more information about your water, or the contents of this report, contact Mike Keesler at (269) 461-6173. For more information about safe drinking water, visit the U.S. Environmental Protection Agency at [www.epa.gov/safewater/](http://www.epa.gov/safewater/).